



Republic of the Philippines
 Department of Science and Technology
PHILIPPINE SCIENCE HIGH SCHOOL MIMAROPA REGION CAMPUS
BIDS AND AWARD COMMITTEE (BAC)
 Rizal, Odiongan, Romblon
 Mobile No. 09278866315 / 09398172212



Certificate No. AJA18-0208

Supplemental/Bid Bulletin

AMENDMENT NO.2

This Amendment No. 1 is issued to modify/amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents, to wit:

Particulars	Reference	<u>Amendment/Addendum</u>
1. Additional Content in TOR.	<ul style="list-style-type: none"> Terms of Reference (TOR) 	<ul style="list-style-type: none"> Objectives <ol style="list-style-type: none"> Provide connections for other systems (CCTV, Info Board system and Time driven clock) <i>will run in our fiber backbone.</i> The Server Room setup shall: <ol style="list-style-type: none"> Structural Specifications <ol style="list-style-type: none"> <i>Door access for server room must be a biometric for security.</i> <i>Door access is stand alone.</i> Equipment Specifications <ol style="list-style-type: none"> Server room should contain fire extinguisher which is suitable for live electrical equipment and smoke detector, adequately maintained and routinely tested. <i>Fire suppression (Fire extinguisher) and detection (Smoke alarm).</i> Power <ol style="list-style-type: none"> <i>Power supply of server room should be placed inside.</i> Location <ol style="list-style-type: none"> <i>Temporarily, the server room will be setup in the ACAD building and will be transferred to Science Laboratory (2nd floor) once the building is completed.</i> Qualification Requirements <ol style="list-style-type: none"> The Contractor must have at least 1 Certified Engineers (Network Engineers with CCNA or CCNP Certification) who are currently employed



Republic of the Philippines
Department of Science and Technology
PHILIPPINE SCIENCE HIGH SCHOOL MIMAROPA REGION CAMPUS
BIDS AND AWARD COMMITTEE (BAC)
Rizal, Odiongan, Romblon
Mobile No. 09278866315 / 09398172212



Certificate No. AJA18-0208

		<p>in the contractor's company trained and certified in the design and installation of cabling System. Must attach certification. <i>Engineers must be a duly licensed (ECE or EE) at least, and/or certified IT personnel - with certification.</i></p> <ul style="list-style-type: none">• Other documentary requirements to be submitted by bidder:<ul style="list-style-type: none">2. <i>20 years warranty for Fiber Optic Cables and 1 year warranty for equipment.</i>• Technical Specifications Lot 2 <u>3300VA SINGLE PHASE UPS</u><ul style="list-style-type: none">• Pn : 2700 W <i>half load only for the back-up time.</i> <u>2KVA SINGLE/SINGLE PHASE UPS</u><ul style="list-style-type: none">• Pn : 1200 W <i>half load only for the back-up time.</i>
--	--	--

The said amendment is posted and available for download at our Website (<http://mrc.pshs.edu.ph/>) and in the PhilGEPs Website posting under bid supplement.

For guidance and information of all concerned.

Very truly yours,


MEKIAM F. BALLAR
PSHS-MRC
BAC Chairperson

Received by the bidder:

Date: