



Republic of the Philippines  
 Department of Science and Technology  
**PHILIPPINE SCIENCE HIGH SCHOOL MIMAROPA REGION CAMPUS**  
**BIDS AND AWARD COMMITTEE (BAC)**  
 Rizal, Odiongan, Romblon  
 Mobile No. 09278866315 / 09398172212

## Supplemental/Bid Bulletin

### ADDENDUM NO. 1

This Addendum No. 1 is issued to modify/amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents, to wit:


Particulars	Reference	Amendment/ <u>Addendum</u>
<b>1. Additional Requirement in PBD</b> (Presentation of Architectural Design and Estimate)	<ul style="list-style-type: none"> <li>• <b>PBD. Page 23.</b> 13.a Additional Requirements</li> <li>• <b>TOR. Page 20.</b> d. Additional Requirements</li> </ul>	<b>13.a Additional Requirements</b>  Authorized Representative must present; <ol style="list-style-type: none"> <li>1. Authorization letter / Special Power of Attorney</li> <li>2. Letter of Intent</li> </ol> <p><b>Note:</b> Non – compliance of the additional requirements (1 &amp; 2) shall not be subjected for the failure or disqualification of the Prospective bidder. These requirements are for the compliance for the statutory and regulatory documents.</p> <p><b>3. <i>Presentation of Architectural Design and Estimate</i></b></p>
<b>2. Additional Minimum Major Equipment Requirements</b> (Pump Crete-Boom Type)	<ul style="list-style-type: none"> <li>• <b>PBD. Page 42.</b> 12.1(b)(iii.3). The minimum major equipment requirements</li> </ul>	Additional Minimum Major Equipment Requirements: <ul style="list-style-type: none"> <li>• <b>1 Unit - Pump Crete (Boom Type), Capacity - (Pipe Diameter 5", Vertical Reach 38.5m, Horizontal Reach 34.7m, Maximum Pressure 1169 psi)</b></li> </ul>
<b>3. Additional Content in TOR.</b> (Other References –	<ul style="list-style-type: none"> <li>• <b>TOR. Page 5.</b> Other References</li> </ul>	Other References  <p><b><i>Soil Bearing Capacity for Laboratory Building I is 160 kpa.</i></b></p>

Soil Bearing Capacity)		
------------------------	--	--

The said amendment is posted and available for download at our Website (<http://mrc.pshs.edu.ph/>) and in the PhilGEPs Website posting under bid supplement.

For guidance and information of all concerned.

Very truly yours,

  
**MERIAM F. BALLAR**  
PSHS-MRC  
BAC Chairperson

Received by the bidder:

\_\_\_\_\_  
Date: